



Fire Department

Mark Rohlifing
Chief

Gerard Washington

Assistant Chief

Brian Smith

Assistant Chief

John Schwengel

Assistant Chief

Contact: Lt. Michael Ball
Milwaukee Fire Department
Director Community Relations
414-397-8494

Mfd-dir-cr@milwaukee.gov

MEDIA ALERT

WHAT: KIDDE PRODUCT SAFETY RECALL

DETAILS: Kidde has recalled two styles of disposable fire extinguishers, both plastic handle fire extinguishers, and plastic push-button fire extinguishers.

This recall does not include Kidde Professional or Badger branded fire extinguishers. Units with metal handles/valve assemblies are not included in this recall.

If you believe that you may have an affected model, go to www.kidde.com/home-safety/en/us/ and click on the “Product Safety Recall Notice” for information on how to determine if your Kidde disposable fire extinguisher is part of the recall, and if so, how to proceed to rectify the situation.

Kidde Product Support: 1-800-880-6788.

###